# **Compact Substations E-House**



**SCK Series** 

SCK-1 | SCK-2 | SCK-3





# **Compact Substations E-House**

## **SCK Series**

SCK type are manufactured as Compact Substations for Power Distribution and as E-houses for Oil & Gas Applications in compliance with Zone2 Hazardous Area Classification, as according to IEC 62271-202 and equipped with special operating and safety systems. SCK series can be manufactured with three different materials depending on the application.

Material Data SCK-1: Steel sheet

SCK-2 : Sandwich Panel

SCK-3: Container

SCK series offer segregated design for MV Switchgear, LV Switchgear, Transformer, Emergency Supply and Batteries with dimensions and specifications as according to the necessity. SCK is equipped with HVAC system, Fire and Smoke detection system, Fire Extinguisher system, Communication system, Internal and External Lighting, Socket outlets, Earthing and Floor insulation.

SCK series compact substations can be design as skid type or mobile on semi-trailer up to IP54 Protection Class.

#### **Application Areas**

- Haddehaneler
- Petrol boru hattı
- Sanayi
- Tersaneler
- · Acil durum ve yedek güç tesisleri
- Maden işletmeleri
- Ulaşım
- Altyapı

#### Standartlar

- IEC 62271-202
- IEC 62271-205
- IEC 62271-200
- IEC 62271-100
- IEC 62271-1
- IEC 60076-1
- IEC 61439-1

#### Color

- RAL 9003 for SCK-1 steel kiosk
- RAL 9002 for SCK-2 sandwich panel
- RAL 9003 for SCK-3 container



# **Compact Substation, E-House**

## **Design And Structural Features**

#### Design

Compact Substations can be designed in accordance with requirement of project. Equipment in Compact Substations can be provided as ex-proof.

#### **Dimension**

Dimensions of Compact Substation can be designed in accordance with requirement of project and are specified in view of the fact that rooms, dimensions of switching equipment, operating conditions and operating area

#### **Base**

Base are made of NPU or NPI shapes according to load on the floor and NPU and NPI shapes are covered hot dip galvanized.

#### **Frame**

Frame of Compact Substation is made of 5 mm Sil St-37 and covered with hot dip galvanized for long term using.

#### **Wall and Roof**

Internal wall and ceiling lining is made of pre-painted corrugated steel sheet with provision for surface or flush mounted items like sockets, switches, fire detectors, lighting fixtures.

As a manufacturer standard total wall and roof thickness;

• for SCK - 1 is 43 mm

Thickness of rock wool/fiber glass wool : 40 mm
Thickness of exterier wall : 2 mm
Thickness of interier wall : 1 mm

• for SCK - 2 is 40 mm

Thickness of rock wool/fiber glass wool : 38.9 mm
Thickness of exterier wall : 0.6 mm
Thickness of interier wall : 0.5 mm

• for SCK - 3 is 52.4 mm

Thickness of rock wool/fiber glass wool : 50 mm
Thickness of exterier wall : 1.2 mm
Thickness of interier wall : 1.2 mm

#### **Doors**

Doors can be opened to  $120^{\circ}$  outside and designed against to 20 J mechanical shock. Doors has rain channel against rain.



Compact Substation Base



Compact Substation Roof



Compact Substation Door

# **Compact Substation, E-House**

## **Technical Specifications**

#### **Interior Lighting, External Lighting**

All rooms in Compact Substation are equipped Lighting System in compliance with standards. Internal and external lighting equipment and sockets can be selected in compliance with Atex certificated for Zone2 Hazardous Area.



#### **Emergency Lighting**

Emergency Exit Armatures are installed on the way of thedoors. Emergency Exit Armatures include emergency lighting unit.



#### **Earthing**

Electrical devices are connected to an isolated earthing busbar. Separate earthing system is used for doors, base, walls and roof to avoid electrical shock in case of touching.



#### Floor

Floor covering is made of non-flammable rubber. It has A1 Classification and 50kV insulation level.,




## Fire Detection and Fire Extinguisher System

All rooms are equipped with fire and smoke detectors. In case of emergency in dangerous situations HVAC system is disabled and warning lights and alarm become active.



#### **Air Conditioning System**

In Compact Substation, HVAC is used to keep stable internal temperature and humidity. Stabilization in all rooms is provided by air ducts.



#### Lifting

When carrying the SCK, the ropes should fastened to the eyebolts carefully.

# **Compact Substation, E-House**

# **Electrical Features And Rooms**



## **MV Switchgear Room**

In Medium Voltage (MV) Switchgear room, Metal Enclosed, Metal Clad, primary and secondary gas insulated switchgear (GIS and RMU) can be used. MV room dimensions are specified in according with equipment dimensions of the room.



#### **Transformer Room**

In Transformer room, dry type transformer and oil type transformer can be used. Dimensions of transformer room are specified in according with power of transformer.





#### LV Switchgear Room

In Low Voltage (LV) room, MCC distribution panel, AC distribution panel, DC distribution panel, metering panel, compensation panel, HVAC panel, fire control panel, UPS, Scada - RTU panel and other requested LV panel can be installed.



#### **Battery Room**

There are Ni-Cd batteries and DC breakers in battery room. If it is required, Zone2 Hazardous Area Classification can be provided in battery room.





#### **Headquarters**

Bayraktar Bul. Şehit Sk. No: 5 34775 Ümraniye, İstanbul, TR Phone : +90 (216) 314 93 20 : +90 (216) 314 93 60 www.aktif.net - info@aktif.net



#### **Germany Office**

Bahnhofstrasse 82-86 35390 Giessen, Germany Phone: +49 176 60940534 www.aktif.net info.de@aktif.net



## **HV Factory**

Akşemsettin Mah. Çatalca Sk. No: 113 06930 Sincan, Ankara, TR Phone: +90 (312) 269 46 02

: +90 (312) 269 45 01 www.aktif.net - info@aktif.net



## LV Factory

Kargalı Hanbaba Organize Sanayi, 2. Sk., No: 5, Hendek, Sakarya, TR Phone: +90 (264) 276 64 50 Fax: +90 (264) 276 64 52

www.aktif.net - info@aktif.net

